

LOCATION 4025 King Mt Hwy CITY CASTANIA
BETWEEN Barney Castle Ln STREET & Gamble Loop STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	319'	6/16/97		
MAIN TO PROP. LINE	3/4"		168			
PROP. LINE TO BLDG.	3/4"		151'			


ENTERS: 4025 BRANCHED INTO:
TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION West side of 4025

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DT
MAIN-SIZE 8' C.I. _____ BARE STEEL _____ COATED STEEL / PLASTIC _____ YEAR INSTALLED 1966

DEPTH: 3 FT. 0 IN. LOCATION North side of Kings Mt Hwy West Bound Ln

"A" P/S READING .90 TOTAL ANODES 1# 0 17# 0 L.R. # 384174

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY