

LOCATION 1807 Kingston Dr. CITY GASTONIA
BETWEEN Fuller STREET & Edgefield STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>104'</u>	<u>4-19-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>4'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>100'</u>			

ENTERS: 1807 BRANCHED INTO: 0
TAP SIZE: 3/8" PRESSURE 600 PSI _____ INCHES W.C. LOCATION 264' 5" W of Edgefield Dr

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1967
DEPTH: 3 FT. 6 IN. LOCATION 26' W of Kingston Dr.

"A" P/S READING .85 TOTAL ANODES 1# 0 17# 0 L.R. # 193512

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>

ENG. DEPT. USE ONLY