

LOCATION 912 Kirkcaldy Yard CITY GASTONIA
BETWEEN Heatherlock DR STREET & End of Caldesack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	195'	3-2-95		
MAIN TO PROP. LINE	3/4"	P	44'			
PROP. LINE TO BLDG.	3/4"	P	151'			


ENTERS: 912 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 280' W. of center of Heatherlock DR

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFSTETTER
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1973

DEPTH: 3 Ft. _____ In. LOCATION 16' S. of center of Kirkcaldy Yard

"A" P/S READING 0.95 TOTAL ANODES 1# 0 17# 0 L.R. # 076990

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY