

LOCATION 204 Kirkwood Dr. CITY Gast.  
BETWEEN Broad St. STREET & Dead end STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>29'</u>			<u>9. 23-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>7'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>22'</u>			

ENTERS: SAME BRANCHED INTO: 210 Kirkwood Dr.  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 194' from of  
Broad St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ← YEAR INSTALLED 1997  
DEPTH: 3 FT. 0 IN. LOCATION N. of Kirkwood Dr.

"A" P/S READING P. TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY