

LOCATION 1910 Kyle Ct. CITY Gastonia
 BETWEEN Beasmer city Rd STREET & Kyle Ct STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	103	4-14-99		
MAIN TO PROP. LINE	"	"	10'			
PROP. LINE TO BLDG.	"	"	93'			

ENTERS: 1910 BRANCHED INTO: —
 TAP SIZE: 1/2 PRESSURE — PSI — INCHES W.C. LOCATION 24' W. of Cop

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY JP Delta
 MAIN SIZE 6" C.I. — BARE STEEL — COATED STEEL ✓ PLASTIC — YEAR INSTALLED 1988

DEPTH: 3 FT 0 IN. LOCATION —

"A" P/S READING 1.20 TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>B</u>	

