

LOCATION 1492 Lake St CITY GASTONIA

BETWEEN Evening Shade STREET & Baker Blvd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>88'</u>	<u>3-17-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>25'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>63'</u>			

ENTERS: 1492 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 449' W. of center of


Evening Shade
PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstutler

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL / PLASTIC _____ YEAR INSTALLED _____

DEPTH: 3 FT. 0 IN. LOCATION 10' S. of center of Lake St

"A" P/S READING 1-1 TOTAL ANODES 1# 0 17# 0 L.R. # 142952

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		