

LOCATION 1636 Laketield circleCITY GastoniaBETWEEN DeadendSTREET & Rain tree

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>101'</u>	<u>10/9/97</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>15'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>86'</u>			

ENTERS: 1636BRANCHED INTO: —TAP SIZE: 3/8PRESSURE 60

PSI

INCHES W.C.

LOCATION


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SEMAIN-SIZE 3"C.I. —BARE STEEL —COATED STEEL —PLASTIC —YEAR INSTALLED 1958DEPTH: 3 FT. 0

IN.

LOCATION

"A" P/S READING 1.2TOTAL ANODES 1# —17# —L.R. # 673290

REMARKS:



Test Station

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New ServiceSPlasticP/S Pipeline Lead - White
Existing MainE

ENG. DEPT. USE ONLY