

LOCATION 1637 Laketield circle CITY Gastonia
BETWEEN RainTree Rd STREET & Deadend STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>136'</u>	<u>12-16-77</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>126'</u>			

ENTERS: 1637 BRANCHED INTO:
TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SE
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1976
DEPTH: 3 FT. 0 IN. LOCATION

"A" P/S READING 1.3 TOTAL ANODES 1# 2 17# _____ L.R. # 856649

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Disse</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY