

LOCATION

604 Lookspore Dr.

CITY

Houston

BETWEEN

Heather Lane

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	72	10-1554		
MAIN TO PROP. LINE	3/4	11	7			
PROP. LINE TO BLDG.	3/4	1	65			

ENTERS:

604

BRANCHED INTO:

TAP SIZE:

1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION

W side of house

PRESSURE TEST: @

100

psi

For

1/4

Hrs.

By

J. Smith

MAIN-SIZE

2

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1993

DEPTH:

2 Ft.

6 In.

LOCATION

18' N/C of

"A" P/S READING


TOTAL ANODES 1#

17#

L.R. #

00462459

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY