

LOCATION 710 Laurel Lane CITY GASTONIA  
BETWEEN Graystone STREET & GARRISON Blvd STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>152'</u>	<u>10/12/94</u>		
MAIN TO PROP. LINE	<u>3/4"</u>		<u>37'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>115'</u>			

ENTERS: 710 BRANCHED INTO:  
TAP SIZE: 3/8" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION East side of 710

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By DT  
MAIN-SIZE 1 1/2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1957  
DEPTH: 2 Ft. 6 In. LOCATION \_\_\_\_\_

"A" P/S READING 60 TOTAL ANODES 1\*0 17\*1 L.R. # 447299

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY