

LOCATION 908 Laurel Lane CITY GANTONIA

BETWEEN Dewey St. STREET & Laurel Lane STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>45'</u>	<u>5-20-97</u>	<u>Relocated Service to</u>	
MAIN TO PROP. LINE				<u>Orig Inst.</u>	<u>Side OF House New</u>	
PROP. LINE TO BLDG.				<u>5-17-94</u>	<u>Addition Being Built on</u>	

ENTERS: 908 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 115' E of C of Laurel Lane


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1994

DEPTH: 3 FT. 0 IN. LOCATION 5' S of C of Eighth Ave.

"A" P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS: Main in Street - No Right of Way.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>

ENG. DEPT. USE ONLY