

LOCATION 1307 Laurel LN CITY GASTONIA

BETWEEN Woodvale STREET & Dumbarton STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PLASTIC	65'	12/27/96		
MAIN TO PROP. LINE	3/4"		12'			
PROP. LINE TO BLDG.	3/4"		53'			

ENTERS: 1307 BRANCHED INTO:

TAP SIZE: 3/8" PRESSURE 60 PSI          INCHES W.C. LOCATION South side of 1307

PRESSURE TEST: @ 100 PSI FOR 4 HRS. BY DT

MAIN-SIZE 2" C.I.          BARE STEEL          COATED STEEL ✓ PLASTIC          YEAR INSTALLED 1964

DEPTH: 3 FT. 0 IN. LOCATION West side of Laurel LN

1/2" P/S READING 1.90 TOTAL ANODES 1# 0 17# 0 L.R. # 737482

REMARKS:

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	<b>S</b>		
P/S Pipeline Lead - White Existing Main	<b>E</b>		

