

LOCATION 1002 Laurel Woods Dr CITY Castroville

BETWEEN CARSON DR. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	88'	4-11-97		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	78'			

ENTERS: 1002 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 114' W. of center of

Laurel Woods Dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hurtado

MAIN-SIZE 6" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1997

DEPTH: 4 FT. 0 IN. LOCATION 13' S. of center of Carson Rd.

"A" P/S READING .9 TOTAL ANODES 1# 0 17# 0 L.R. # 227285

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY