

LOCATION 1005 Laurel Woods Dr. CITY Gastonia
BETWEEN Carson STREET & Candlewood STREET


| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|-----------|------------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>P</u> | <u>98'</u> | <u>5-22-97</u> | | |
| MAIN TO PROP. LINE | <u>11</u> | <u>11</u> | <u>43'</u> | | | |
| PROP. LINE TO BLDG. | <u>11</u> | <u>11</u> | <u>45'</u> | | | |

ENTERS: 1005 BRANCHED INTO:
TAP SIZE: Carson PRESSURE 60 PSI _____ INCHES W.C. LOCATION 231' S of C of Carson

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BC
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997
DEPTH: 3 FT. IN. LOCATION 16' W of C of Laurel Woods

"A" P/S READING plastic TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:

|  | Test Station | | | ENG. DEPT. USE ONLY |
|--|--|----------|----------|---------------------|
| | Reading & Location | Lead | Volts | |
| | P/S Pipeline Lead - Red New Service | <u>R</u> | <u>P</u> | |
| | P/S Pipeline Lead - White Existing Main | <u>E</u> | | |