

LOCATION 1102 Laurel Woods Dr. CITY GASTONIA
BETWEEN Graywood Dr. STREET & Candlewood Dr. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|-------------|----------|------------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>94'</u> | <u>4-17-98</u> | | |
| MAIN TO PROP. LINE | <u>3/4"</u> | <u>P</u> | <u>15'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>79'</u> | | | |


ENTERS: 1102 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 31' S. of center of
Graywood Dr.

PRESSURE TEST: @ 100 PSI FOR 114 HRS. BY S. HUFFSTETTER
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION: 15' W. of center of Laurel Woods Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 261011

REMARKS:



| Test Station | | |
|--|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY