

LOCATION 1114 Laurel Woods Dr CITY Gastonia
BETWEEN Candlewood Dr STREET & Deer End. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|-------------|----------|------------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>28'</u> | <u>1-20-98</u> | | |
| MAIN TO PROP. LINE | <u>3/4"</u> | <u>P</u> | <u>10'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>18'</u> | | | |


ENTERS: 1114 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 101' S. of center of
Laurel Woods Dr.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hartfelder
MAIN-SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 2 FT. 0 IN. LOCATION 283' E. of center of Candlewood Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 23098

REMARKS:



| Test Station | | |
|--|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY