

LOCATION 1242 Laurel Woods Dr. CITY Winston-Salem
BETWEEN See Jay Ct. STREET & Crowders Woods Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>112'</u>	<u>1-20-03</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>14'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>68'</u>	<u>"</u>		

ENTERS 1242 BRANCHED INTO 0
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 240' East


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY J. Woods
17' center of See Jay Ct.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1969

DEPTH 3' FT 0" IN LOCATION 20' north of center of Laurel Woods Dr.

"A" P/S READING 11.1 TOTAL ANODES 1# 0 17# 0 LR # 00004705

REMARKS New Plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>11.1</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	