

LOCATION 1519 Livingston Ct CITY CASTONIA
BETWEEN Indigo Run STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>66'</u>	<u>11/6/95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>		<u>12'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>54'</u>			

ENTERS: 1519 BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 P.S.I. INCHES W.C. LOCATION N side of 1519

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1994
DEPTH: 3 Ft. 0 In. LOCATION West side of Livingston Ct

"A" P/S READING 0 TOTAL ANODES 1* 0 17* 0 L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY