

LOCATION 2211 S. Lee St CITY Columbia
BETWEEN Perry STREET & S. New Hope Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED <input checked="" type="checkbox"/>	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>D</u>	<u>42'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>D</u>	<u>5'</u>			<u>3-22-85</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>D</u>	<u>37'</u>			

ENTERS: 2211 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 psi For 14 Hrs. By LP

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992

DEPTH: 3 Ft. 6 In. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY