

LOCATION 4619 Lenden Hall Ct CITY Casteria
BETWEEN Roberts Fork Ct STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>94'</u>	<u>8-7-99</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>89'</u>			

ENTERS: 4619 BRANCHED INTO 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST @ 100 PSI FOR 14 HRS BY EP

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998

DEPTH: 2 FT 6 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>1.52</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	