

LOCATION 4620 Lenden Hall Ct CITY Gastonia

BETWEEN Abbotsford STREET & Dead end STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>120'</u>	<u>11-2-98</u>		
MAIN TO PROP. LINE	<u>11'</u>	<u>1</u>	<u>43'</u>			
PROP. LINE TO BLDG.	<u>1'</u>	<u>11</u>	<u>77'</u>			

ENTERS: 4620 BRANCHED INTO: —

TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 19' S. of Cop

Lenden Hall


PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY JP

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY