


LOCATION 511 Lenox Ave CITY GASTONIABETWEEN Boyer STREET & Morris STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>85'</u>			<u>8/3/96</u>
MAIN TO PROP. LINE	<u>3/4"</u>		<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>25'</u>			

ENTERS: 511 BRANCHED INTO:TAP SIZE: 1/2" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION W side of 511PRESSURE TEST: @ 60 PSI FOR 1/2 HRS. BY DPMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1994DEPTH: 2 FT. 0 IN. LOCATION West side of Lenox Ave"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 414980

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY