

LOCATION 2001 LESLIE DR CITY GAST  
BETWEEN ASHTON PL STREET & PAMELA ST STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>14'</u>		<u>TIE OVER</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: SAME BRANCHED INTO:  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 25 E From (C) OF PAMELA

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JK  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 1997  
DEPTH: 3 FT. 0 IN. LOCATION EAST SIDE OF PAMELA

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY