

LOCATION 5201 Lewis RdCITY GASTONIABETWEEN LewisSTREET & Hollywood

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>310'</u>	<u>1-19-85</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>270</u>			

ENTERS: 5201

BRANCHED INTO:

TAP SIZE: 3/8PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C.LOCATION 11' S ofChapel GrovePRESSURE TEST: @ 100 psi For 1 1/2 Hrs. By M. ParkerMAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1963DEPTH: 3 Ft. 0 In. LOCATION 453' E of Lewis"A" P/S READING 1.1 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # 585349

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>p-riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY