


LOCATION 5327 LEWIS RD CITY CASTONIABETWEEN BOYD RD STREET & STONECLIFF DR STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	$\frac{3}{4}$	plastic	426'	4-21-98		
MAIN TO PROP. LINE	$\frac{3}{4}$	plastic	20'			
PROP. LINE TO BLDG.	$\frac{3}{4}$	plastic	406'			

ENTERS: 5327 BRANCHED INTO: 0TAP SIZE: $\frac{3}{8}$ PRESSURE 60 PSI _____ INCHES W.C. LOCATION 1030' S OF C OF BOYD RDPRESSURE TEST: @ 100 PSI FOR 14 HRS. BY R.L.MAIN-SIZE 6" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1964DEPTH: 3' FT. 0 IN. LOCATION 13' E OF C OF LEWIS RD"A" P/S READING 0.6 TOTAL ANODES 1# 0 17# 1 I.R. # 0272959

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	Riser

ENG. DEPT. USE ONLY