

LOCATION 104 N. Liberty St CITY Astoria

BETWEEN W Main STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	78	10-8-94		
MAIN TO PROP. LINE	3/4	"	41			
PROP. LINE TO BLDG.	3/4	"	37			

ENTERS: 104 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION side house


PRESSURE TEST: @ 100 psi For 14 Hrs. By Bone

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1991

DEPTH: 2 Ft. 6 In. LOCATION 160' E of Rt

"A" P/S READING _____ P TOTAL ANODES 1# _____ 17# _____ L.R. # 00457760

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY