

LOCATION 1413 Liberty OAK CT. CITY GASTONIA

BETWEEN Colony Ridge STREET & Cul-d-sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>65'</u>	<u>11/17/95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>		<u>15'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>50'</u>			

ENTERS: 1413 BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION West side of 1413


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 3 Ft. 0 In. 0 LOCATION South side of Liberty OAK

"A" P/S READING 0 TOTAL ANODES 1* 0 17* 0 L.R. # 018296

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY