

LOCATION 113 W. LINCOLN AVECITY GASTONIABETWEEN FALLSSTREET & MARIETTA

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Ø</u>	<u>6' stub</u>	<u>TIED OVER</u>		
MAIN TO PROP. LINE			<u>54' EXIST</u>	<u>11-1-96</u>		
PROP. LINE TO BLDG.						

ENTERS: 113

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 159' E OFFALLSPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M. ParkerMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 96DEPTH: 3 FT. 0 IN. LOCATION 12' South of W Lincoln Ave."A" P/S READING Ø TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-RIDE</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY