

LOCATION 116 W. Lincoln AVE. CITY GASTONIA

BETWEEN N. Marietta St. STREET & Falls St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>6'</u>			<u>5-31-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>6'</u>			

ENTERS: 116 W. Lincoln St. BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 104' East from Center of Falls Ave


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY ml

MAIN SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC / YEAR INSTALLED 1996

DEPTH: 1 FT. 6 IN. LOCATION 63' North of W. Lincoln St.

"A" P/S READING P TOTAL ANODES 1# _____ T7# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY