

LOCATION 204 W. Lincoln Ave CITY East
BETWEEN Falls St. STREET & N. York St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>82'</u>			<u>6-6-96</u>
MAIN TO PROP. LINE	<u>1"</u>	<u>"</u>	<u>36'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>"</u>	<u>46'</u>			

ENTERS: 204 W. Lincoln Ave BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 92' West from @ of Falls St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY mf
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996
DEPTH: 3 FT. 0 IN. LOCATION South side of W. Lincoln

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>		
	P/S Pipeline Lead - White Existing Main	<u>E</u>		