

LOCATION 208 W. LINCOLN AVE. CITY East.  
BETWEEN Falls St. STREET & N. York St STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>43'</u>			<u>6-7-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>29'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>14'</u>			

ENTERS: 208 W. LINCOLN Ave BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 339' East from @ of N. York St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY mf  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996  
DEPTH: 3 FT. 0 IN. LOCATION Southside of W Lincoln Ave

"A" P/S READING P. TOTAL ANODES 1# 17# L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY