

LOCATION 213 W. Lincoln Ave CITY GAST.

BETWEEN N. York St. STREET & Falls Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>51'</u>			<u>6-11-96</u>
MAIN TO PROP. LINE	<u>11</u>	<u>"</u>	<u>4'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>"</u>	<u>47'</u>			

ENTERS: 213 W. Lincoln Ave BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 145' East from @ of N. York St.


PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY mlf

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION South Side of W. Lincoln Ave

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY