

LOCATION 607 W Lincoln Ave. CITY Gastonia

BETWEEN Pryor St. STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>42 Ft</u>			<u>1-13-97</u>
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>2 1/2 Ft</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>40 Ft.</u>			

ENTERS: Same BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.H.J.

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED Aug 1997

DEPTH: 3 FT. IN. LOCATION Southside of W. Lincoln Ave.

"A" P/S READING Plastic TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY