

LOCATION 609 W Lincoln Ave. CITY Eastonia

BETWEEN Prior st. STREET & Dead end STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P.</u>	<u>33 ft</u>			<u>1-13-97</u>
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>1 ft</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>32 ft</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 440 ft. From ⊙

of Prior st.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.H.d

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION South side of W. Lincoln Ave.

"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY