

LOCATION 502 N. Pryor 626 W. Lincoln Ave CITY GASTON, N.C.
BETWEEN _____ STREET & _____ STREET

	SIZE	TYPE	SO ₂ LENGTH <u>626</u>		INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>35'</u>	<u>100'</u>	<u>4-5-90</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>Plastic</u>	<u>-</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>35'</u>	<u>70'</u>			

ENTERS: 502 N. Pryor + 626 W. Lincoln BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 20 P.S.I. _____ INCHES W.C. LOCATION 79' E. of CL of Pryor St


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By F. Johnson

MAIN SIZE Service 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1989

DEPTH: 1 Ft. 6 In. LOCATION 100' N. of CL of Lincoln Ave

"A" P/S READING _____ TOTAL ANODES 1# 0 17# 0 L.R. # 77575, 77574

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	1

ENG. DEPT. USE ONLY