

LOCATION	3296 LINCOLN LN.		CITY	GASTON, VA	
BETWEEN	Cross Creek DR.	STREET &	DEAD END.	STREET	

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	106'	5-21-98		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	101'			

ENTERS:	3296		BRANCHED INTO:		
TAP SIZE:	1/2	PRESSURE	60 PSI	INCHES W.C.	LOCATION
				847' N. of center of Cross Creek DR	


PRESSURE TEST: @	100	PSI	FOR	1/4	HRS.	BY	S. Huffstetter
------------------	-----	-----	-----	-----	------	----	----------------

MAIN-SIZE	2"	C.I.		BARE STEEL		COATED STEEL	<input checked="" type="checkbox"/>	PLASTIC		YEAR INSTALLED	1979
-----------	----	------	--	------------	--	--------------	-------------------------------------	---------	--	----------------	------

DEPTH:	3 FT.	0 IN.	LOCATION	16' E. of center of LINCOLN LN.		
--------	-------	-------	----------	---------------------------------	--	--

"A" P/S READING	1.3	TOTAL ANODES 1#	0	17#	0	L.R. #	337945
-----------------	-----	-----------------	---	-----	---	--------	--------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY