

LOCATION 2197 Linda St. CITY Canton

BETWEEN Audrey Dr STREET & Leslie Dr STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|-------------|----------|------------|-----------|---------|----------------|
| MAIN TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>30'</u> | | | <u>1-17-98</u> |
| MAIN TO PROP. LINE | <u>3/4"</u> | <u>P</u> | <u>10'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>20'</u> | | | |

ENTERS: 2197 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 94' w. of center of

Linda St


PRESSURE TEST: @ 150 PSI FOR 1 1/4 HRS. BY S. Hultgren

MAIN-SIZE 3/4" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998

DEPTH: 2 FT. 0 IN. LOCATION 19' N. of center of Leslie Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. #

REMARKS:

|  | Test Station | | |
|--|--|----------|-------|
| | Reading & Location | Lead | Volts |
| | P/S Pipeline Lead - Red New Service | S | |
| | P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY