

LOCATION 307 Linden cir

CITY Gast.

BETWEEN Broad st.

STREET & Linden cir

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P.	56'		9-	29-97
MAIN TO PROP. LINE	"	"	8'			
PROP. LINE TO BLDG.	"	"	48'			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4"

PRESSURE 60 PSI

INCHES W.C.

LOCATION 332' From (C) of

Broad st.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.

MAIN-SIZE 2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC ☒

YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN.


LOCATION S.O.F Linden cir

"A" P/S READING

TOTAL ANODES 1# 17#

L.R. #

REMARKS:



Test Station

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

S

P/S Pipeline Lead - White
Existing Main

E

ENG. DEPT. USE ONLY