

LOCATION 310 Linden Cir CITY Gast.  
 BETWEEN Linden cir 300 STREET & Broad St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>112'</u>		<u>10-1-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>46'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>66'</u>			

ENTERS: SAME BRANCHED INTO:  
 TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 113' from @ of Linden cir 300

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.  
 MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED P.  
 DEPTH: 3 FT. 0 IN. LOCATION \_\_\_\_\_

"A" P/S READING P. TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY