

LOCATION 1402 Lineberger St

CITY Gastonia

BETWEEN Hillcrest

STREET & Dearden St

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	95'		1-	14-98
MAIN TO PROP. LINE	"	"	54'			
PROP. LINE TO BLDG.	"	"	43'			

ENTERS: 1402

BRANCHED INTO: —

TAP SIZE: 3/4	PRESSURE 60 PSI	INCHES W.C.	LOCATION
---------------	-----------------	-------------	----------


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SE

MAIN-SIZE 2"	C.I.	BARE STEEL	COATED STEEL	PLASTIC <input checked="" type="checkbox"/>	YEAR INSTALLED 1997
--------------	------	------------	--------------	---	---------------------

DEPTH:	FT.	IN.	LOCATION
--------	-----	-----	----------

"A" P/S READING Plastic	TOTAL ANODES 1# — 17# —	L.R. # —
-------------------------	-------------------------	----------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	Risk	Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY