

LOCATION 1411 Linoberger St CITY Castania
BETWEEN Hillcrest STREET & \ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	114'			11/18/98
MAIN TO PROP. LINE	3/4"		15'			
PROP. LINE TO BLDG.	3/4"		99'			


ENTERS: 1411 BRANCHED INTO:
TAP SIZE: 1 1/2" PRESSURE 60 PSI INCHES W.C. LOCATION West Side of 1411

PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY DT
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION West Side of Linoberger St

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 010-443

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY