

LOCATION 1413 Linberger st CITY GASTON  
BETWEEN Hillcrest STREET & STREET

	SIZE	TYPE	LENGTH	tie over	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	59'	11/10/98		
MAIN TO PROP. LINE	3/4"		3'			
PROP. LINE TO BLDG.	3/4"		56'			

ENTERS: 1413 BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION South side of 1413


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DT

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. 0 LOCATION West side of Linberger

"A" P/S READING 10 TOTAL ANODES 10 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: tied over 56' of ex Plastic service to New  
2" main with 3' of Plastic pipe and to



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY