

LOCATION 1416 Linberger CITY Boston
BETWEEN Hillcrest STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>155'</u>			<u>11/10/98</u>
MAIN TO PROP. LINE	<u>3/4"</u>		<u>42'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>113'</u>			

ENTERS: 1416 BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION South side of 1416


PRESSURE TEST: @ 100 PSI FOR 4 HRS. BY DT

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC / YEAR INSTALLED 1992

DEPTH: 3 FT. 0 IN. 0 LOCATION West side of Linberger

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 110443

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY