


LOCATION 311 LINSBURY CR. CITY GASTONIA
 BETWEEN HICKORY HOLLOW RD STREET & CREEK RIDGE DR STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>80'</u>	<u>11.16.01</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>75'</u>			

ENTERS 311 BRANCHED INTO _____
 TAP SIZE. 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION S. side of 311

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY Tin
 MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC - YEAR INSTALLED 2001
 DEPTH 3 FT IN _____ LOCATION s.w. part of cul de sac
 "A" P/S READING n/a TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	