


LOCATION 326 Linsbury Ct CITY Cartersville
 BETWEEN Creek Ridge Ct STREET & Cal-de-8th STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>101'</u>	<u>6-12-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>38'</u>			
PROP. LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>63'</u>			

 ENTERS. 326 BRANCHED INTO:
 TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 130' SW of center of Creek Ridge Dr.
 PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.H.
 MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 2000
 DEPTH: 3 FT 0 IN LOCATION 10' NW. of center of Linsbury Ct.
 "A" P/S READING 7 TOTAL ANODES 1# 0 17# 0 I.R. # 435606

REMARKS.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	