

LOCATION 359 Limbury Ct. CITY Castana
BETWEEN _____ STREET & _____ STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>62'</u>	<u>3-25-00</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>4'</u>			
PROP. LINE TO BLDG.	<u>2 1/4"</u>	<u>P</u>	<u>50'</u>			

ENTERS: 359 BRANCHED INTO: _____
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 44' SW of photo of

PRESSURE TEST: @ 100 PSI FOR 24 HRS. BY S. G.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2000
DEPTH: 3 FT. 0 IN. LOCATION 18' NW. of center of Limbury Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 237020

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	