

LOCATION 424 Linsbury Ct. CITY Castonia
 BETWEEN Dannell Dr STREET & Hickory Hollow Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	100'	6-12-02		
MAIN TO PROP LINE	5/8"	P	40'	"		
PROP LINE TO BLDG	5/8"	P	60'	"		

ENTERS 424 BRANCHED INTO 4
 TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 188' north


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woods center of Hickory Hollow Rd.

MAIN-SIZE 4" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2001

DEPTH 3' FT 0" IN LOCATION 19' West of center of Linsbury Ct.

"A" P/S READING N/A TOTAL ANODES 1# 1 17# 0 LR # 00132466

REMARKS New Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	E	<u>rise</u>