

LOCATION 456 Linsbury Ct. CITY Gastonia
BETWEEN DONNELL DR. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	118'	10-14-02		
MAIN TO PROP LINE	5/8"	P	35'			
PROP LINE TO BLDG	5/8"	P	83'			

ENTERS 456 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 301' N. of center of Donnell Dr

PRESSURE TEST @ 160 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2002

DEPTH 3 FT 0 IN LOCATION 17' W. of center of Linsbury Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 300085

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

