

LOCATION 464 Linsbury Ct. CITY Gastonia
BETWEEN Donnell Dr STREET & Hickory Hollow Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	80'	10-12-02		
MAIN TO PROP LINE	5/8"	P	11'	"		
PROP LINE TO BLDG	5/8"	P	69'	"		

ENTERS 464 BRANCHED INTO 0
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 464' north of
center of Donnell Dr.


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY D. Wood

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 2001

DEPTH 3' FT 0" IN LOCATION 35' East of center of Linsbury Ct.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 00138469

REMARKS New plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Plastic
P/S Pipeline Lead - White Existing Main	E	Riser