

LOCATION 473 Linsbury CT CITY Castana

BETWEEN Donnell Dr STREET & STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|-------------------|-------------|----------|------------|----------------|---------|---------|
| MAIN TO BLDG | <u>5/8"</u> | <u>P</u> | <u>91'</u> | <u>8-27-03</u> | | |
| MAIN TO PROP LINE | <u>5/8"</u> | <u>P</u> | <u>10'</u> | | | |
| PROP LINE TO BLDG | <u>5/8"</u> | <u>P</u> | <u>81'</u> | | | |

ENTERS 473 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 40 PSI INCHES W C LOCATION 8' NW. of center of Linsbury CT


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SLH

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 2001

DEPTH 3 FT 0 IN LOCATION 36' NE of center of Cul-de-Sac

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR #

REMARKS



| Test Station | | |
|--|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |